

Spill Summary Report for NRC Report #1052194

Report Date: 9/14/2022

Report Time: 4:03 PM EDT

Region II Hotline Log Entry Information

Data ID: 1417819

Date Of Report: 6/29/2013

NRC #: 1052194

State #:

ERNS #:

Material Type: Oil

Receiver: Daly

Material / Amount:

OIL, MISC: TRANSFORMER (DIELECTRIC FLUID) (925 GALLON(S));

Location:

Street:
 City: BROOKLYN
 County: KINGS(BROOKLYN)
 State: NY
 Latitude:
 Longitude:

Source of Pollution:

CON EDISON

Water Body:

State Or EPA Responded:

Initial EPA Action:

Contacted Con Edison

Status:

2 - Closed

URL:

Associated Action Reports

DataID: 0631276

Date: 6/29/2013	Time: 16:00	
Duty Officer/Responder Name: Daly	NRC Report #: 1052194	Hotline Log DataID: 1417819
Action Information		
Description: OSC Daly contacted Con Edison. Apparently there is a discrepancy in their tank readings gauge somewhere between Brooklyn substation and Jersey City Hudson station. This is just a potential release and Con Edison will send another report if actual release is discovered.		
Follup-Up:		
Person Contacted		
Name: Con Edison Organization: Con Edison Phone #: 212-580-6763		

NRC Spill Report

NATIONAL RESPONSE CENTER 1-800-424-8802

GOVERNMENT USE ONLYGOVERNMENT USE ONLY***

Information released to a third party shall comply with any
 applicable federal and/or state Freedom of Information and Privacy Laws

Incident Report # 1052194

INCIDENT DESCRIPTION

**** THIS IS A POTENTIAL RELEASE ****

*Report taken by: MST2 BRANDY HUGGINS at 15:43 on 29-JUN-13

Incident Type: FIXED

Incident Cause: UNKNOWN

Affected Area:

The incident was discovered on 29-JUN-13 at 15:27 local time.

Affected Medium: NON-RELEASE (N/A)

REPORTING PARTY

Name: TOM ENRIGHT
Organization: CON EDISON
Address: 128 WEST END AVE.
 NEW YORK, NY 10003

ALTERNATE Phone: (212) 5806763

INCIDENT LOCATION

FARRAGUT SUBSTATION County: KINGS (BROOKLYN)

89 JOHN STREET

City: BROOKLYN State: NY

FROM SUBSTATION ENTRY UTILITY BROOKLYN UNDERWATER TO NJ HUDSON PSE&G JERSEY CITY

POTENTIALLY RELEASED MATERIAL(S)

CHRIS Code: OTF Official Material Name: OIL, MISC: TRANSFORMER

Also Known As: OIL, MISC: TRANSFORMER (DIELECTRIC FLUID)

Qty Released: 925 GALLON(S)

DESCRIPTION OF INCIDENT

CALLER IS REPORTING THAT THERE WAS AN INCONSISTENCY IN GAUGE READINGS SOMEWHERE
 BETWEEN THE BROOKLYN SUBSTATION UNDERWATER TO THE JERSEY CITY HUDSON STATION. THE

INCIDENT DETAILS

Package: N/A
Building ID:
Type of Fixed Object: OTHER
Power Generating Facility: UNKNOWN
Generating Capacity:
Type of Fuel:
NPDES:
NPDES Compliance: UNKNOWN

IMPACT

Fire Involved: NO Fire Extinguished: UNKNOWN
INJURIES: NO Hospitalized: Empl/Crew: Passenger:
FATALITIES: NO Empl/Crew: Passenger: Occupant:
EVACUATIONS: NO Who Evacuated: Radius/Area:
Damages: NO

		Hours	Direction of
<u>Closure Type</u>	<u>Description of Closure</u>	<u>Closed</u>	<u>Closure</u>
Air:	N		
Road:	N		Major Art _N
Waterway:	N		
Track:	N		

Passengers Transferred: NO
Environmental Impact: NO
Media Interest: NONE Community Impact due to Material:

REPORTING PARTY

Type of Organization: PUBLIC UTILITY

SUSPECTED RESPONSIBLE PARTY

Name: TOM ENRIGHT
Organization: CON EDISON
Address: 128 WEST END AVE.
 NEW YORK, NY 10003
ALTERNATE Phone: (212)5806763
Type of Organization: PUBLIC UTILITY

REMEDIAL ACTIONS

PFT TRUCKS ARE RUNNING THE LENGTH OF THE FEEDERS TO DETERMINE IF THERE IS A LEAK
AND/OR WHERE. COORDINATING WITH THE NJ SIDE FOR INVESTIGATION OF THE SYSTEM.
Release Secured: UNKNOWN
Release Rate:
Estimated Release Duration:

WEATHER

ADDITIONAL AGENCIES NOTIFIED

Federal:
State/Local:
State/Local On Scene:
State Agency Number:

NOTIFICATIONS BY NRC

ATLANTIC STRIKE TEAM (MAIN OFFICE)
29-JUN-13 15:52 (609)7240008
DHS PROTECTIVE SECURITY ADVISOR (PSA DESK)
29-JUN-13 15:52 (703)2355724
DOT CRISIS MANAGEMENT CENTER (MAIN OFFICE)
29-JUN-13 15:52 (202)3661863
U.S. EPA II (MAIN OFFICE)
29-JUN-13 15:55 (732)3214370 DALY
NATIONAL INFRASTRUCTURE COORD CTR (MAIN OFFICE)
29-JUN-13 15:52 (202)2829201
NJ OFC HMLND SECURITY & PREPAREDNESS (COMMAND CENTER)
29-JUN-13 15:52 (609)9636817
NJ STATE POLICE (MARINE SERVICES BUREAU)
29-JUN-13 15:52 (609)9636900

NOAA RPTS FOR NY (MAIN OFFICE)
29-JUN-13 15:52 (206)5264911
NATIONAL RESPONSE CENTER HQ (AUTOMATIC REPORTS)
29-JUN-13 15:52 (202)2671136
BUREAU TOXIC SUBSTANCE (MAIN OFFICE)
29-JUN-13 15:52 (518)4027810
NY STATE DEC SPILL HOTLINE (MAIN OFFICE)
29-JUN-13 15:52 (518)4577362
SECTOR NEW YORK (COMMAND CENTER)
29-JUN-13 15:53 (718)3544356 COLON
NJ DEP POC: DUTY OFFICER (MAIN OFFICE)
29-JUN-13 15:52 (609)5844551
USCG DISTRICT 1 (COMMAND CENTER)
29-JUN-13 15:52 (617)2238555

ADDITIONAL INFORMATION

NOTIFICATIONS TO DEC, DEP, PSC (BULK), AND A NJ AGENCY WILL BE CONTACTED NEXT.

*** END INCIDENT REPORT # 1052194 ***

Report any problems or Fax number changes by calling 1-800-424-8802

PLEASE VISIT OUR WEB SITE AT <http://www.nrc.uscg.mil>